



Declaration of Performance DoP

No. 002-CPR-2019

1. Product identification code: Delta Compact Quad+ sub panel
2. Type, batch or serial number: Part number:
271807.2
271807.4
271807.18
3. Intended use: Fire detection and fire alarm systems installed in buildings
4. Name and contact address of the manufacturer: Honeywell Life Safety AS
P.O. Box 3514
N-3007 Drammen
Norway
e-mail: fire.safety@honeywell.com
5. Name and contact address of authorized representative: Not applicable
6. System or systems of assessment and verification of constancy of performance of the construction product: System 1
7. In case of the declaration of performance concerning a construction product covered by a harmonized standard:

Name and identification number of the notified body: Nemko AS, no. 0470

has performed type testing in accordance with system 1 and has issued following certificate of constancy of performance: 0470-CPR-0040
8. In case of the declaration of performance concerning a construction product for which a European Technical Assessment has been issued: Not applicable



9. Declared performance:

Essential characteristics	Performance	Harmonized technical specification
Performance under fire conditions	Passed	EN 54-2:1997 + A1:2006 Art.: 4, 5, 7
Response delay (response time to fire)	Passed	EN 54-2:1997 + A1:2006 Art.: 7.1, 7.7, 7.11, 7.12
Operational reliability	Passed	EN 54-2:1997 + A1:2006 Art.: 4, 5, 6, 7, 8, 9, 10, 11, 12, 13, 14
Durability of operational reliability, Temperature resistance	Passed	EN 54-2:1997 + A1:2006 Art.: 15.4
Durability of operational reliability, Vibration resistance	Passed	EN 54-2:1997 + A1:2006 Art.: 15.6, 15.7, 15.15
Durability of operational reliability, Electrical stability	Passed	EN 54-2:1997 + A1:2006 Art.: 15.8 to 15.13
Performance of power supply	Passed	EN 54-4:1997 + A2:2006 Art.: 4, 5, 6
Operational reliability	Passed	EN 54-4:1997 + A2:2006 Art.: 4, 5, 6, 7, 8
Durability of operational reliability, Temperature resistance	Passed	EN 54-4:1997 + A2:2006 Art.: 9.5
Durability of operational reliability, Vibration resistance	Passed	EN 54-4:1997 + A2:2006 Art.: 9.7, 9.8, 9.15
Durability of operational reliability, Electrical stability	Passed	EN 54-4:1997 + A2:2006 Art.: 9.9 to 9.13
Durability of operational reliability, Humidity resistance	Passed	EN 54-4:1997 + A2:2006 Art.: 9.6, 9.14
Durability of operational reliability, Humidity resistance	Passed	EN 54-2:1997 + A1:2006 Art.: 15.5, 15.14

The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9. This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Sven-Ingve Rasmussen, Interim R&D Leader HSF Nordics

Name and position

Drammen, 19.12.2019

Place and date of issue

Signature

NORWAY / Honeywell Life Safety AS

Lierstranda Industriområde, P.O. Box 3514, 3007 Drammen, Norway

E-mail: fire.safety@honeywell.com

Phone: +47 32 24 48 00

Internet: www.eltek-fs.com